



MASTERFLUX
By *Tecumseh*

Brushless DC Motor Controller Product Specification Assembly 025A0153

September 16, 2009

Revision History

ECN #	Date	Rev	Description	By
EC27994	9/3/2009	A	Initial Release	D. Stahl
EC28318	091609	B	Changed fault timer to match software	D. Stahl

WARRANTY INFORMATION

IMPORTANT PRODUCT NOTICE AND WARRANTY INFORMATION

All statements, technical information or data related to Masterflux products are based on information believed to be reliable. However, no representation or warranty, express or implied, is made as to their completeness, accuracy, fitness for a particular purpose or any other matter, including, without limitation, that the practice or application of any such statements, technical information or data is free of patent infringement or other intellectual property misappropriation.

All information provided in this specification is intended for persons having the requisite knowledge, skill, and expertise to properly and completely evaluate such information. Masterflux shall not be responsible or liable for the use, application or implementation of the information provided herein, and all such information is to be used at the risk, and in the sole judgment and discretion, of such persons, their employees, advisors and agents and only after their independent evaluation and determination that the product is suitable for the application intended by such persons.

Masterflux is not in the business of providing technical, engineering or operational information for a fee, and, therefore, any such information is provided as an accommodation and without charge. Masterflux reserves the right to make changes to its products or to discontinue any product at any time without notice, and advises customers to obtain the latest relevant information prior to ordering.

Limited WARRANTY; DISCLAIMER OF WARRANTY; LIMITED REMEDY; LIMITED LIABILITY

All Masterflux products are sold subject to the terms and conditions of sale supplied at the time of order acknowledgement, including, but not limited to, those pertaining to warranty (as stated in its "Warranty to Original Equipment Manufacturers"), patent infringement, and limitation of liability. MASTERFLUX MAKES NO OTHER WARRANTIES INCLUDING, BUT NOT LIMITED TO, ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE INCLUDING, WITHOUT LIMITATION, ANY WARRANTY THAT MASTERFLUX PRODUCTS ARE SUITABLE OR FIT FOR USE IN ANY HUMAN SAFETY OR LIFE SUPPORT SYSTEMS. If a Masterflux product is found to be defective in materials or workmanship within the warranty period set forth in the "Warranty to Original Equipment Manufacturers," Masterflux's sole and exclusive obligation, exercisable in its sole discretion, shall be to repair or replace the product or refund the purchase price of the product as more fully set forth in the "Warranty to Original Equipment Manufacturers."

Masterflux will not be liable for any loss or damage arising from any Masterflux product, whether direct, indirect, special, incidental or consequential, regardless of the legal theory asserted, even if Masterflux shall have been advised of the possibility of such potential loss or damage.



Table Of Contents

Revision History	1
WARRANTY INFORMATION	2
Table Of Contents	3
Device Overview	4
Features	4
General Product Description	4
Operation.....	5
Power On/Off Switch.....	5
Speed Control.....	5
Tachometer Output	6
Fault Indicator Output.....	6
Fan Power	6
Electrical Ratings / Specifications	6
Absolute Maximum Ratings	6
Electrical Characteristics	7
Connectors	8

Device Overview

Features

- **Locked rotor detection**
- **Motor Drive FET thermal shutdown**
- **Motor case thermal shutdown**
- **Under/Over voltage shutdown**
- **Low speed protection**
- **Current limiting**
- **Fault output**
- **Tachometer output**
- **2 Fan Power Outputs (optional)**
- **Fault code LED**
- **UL listed**

General Product Description

The 025A0153 Motor Controller employs the use of an ST microprocessor for control of the motor resulting in improved control/performance.

The 025A0153 Motor Controller has been designed to provide efficient control and monitoring of a DC powered brushless hermetic compressor. The controller provides a constant speed as specified by the speed set-point input, independent of motor voltage and load unless one of the following limitations is exceeded. Current limit, this is where the average current the motor requires to maintain the commanded speed exceeds 45 amps. If the load requires more than 45 amps then the speed will be reduced accordingly. Voltage limitation, this is where the motor supply voltage is not high enough to achieve the commanded speed.

Fault conditions are monitored continuously. Upon detection of a fault, the motor is shut down. The motor controller will attempt to restart the motor after the fault condition is cleared. The controller will indicate the fault state by a TTL level output. For a Locked Rotor fault, Stall fault or Start up Failed fault the controller will delay for 20 seconds before attempting to restart. For Under Voltage fault, Over Voltage fault or Module Overheat fault the controller will delay for ten seconds before attempting to restart. For the Shell Over Temperature fault the controller will delay for five seconds then recheck the shell input. If the shell input is not active the controller will attempt a restart. Once the fault condition is cleared and the motor is restarted then the TTL level fault indicator is cleared. For an Over-current fault the controller will delay for sixty seconds before attempting to restart. If ten Over-current faults occur the controller will cease trying to restart the motor and power must be cycled off and on. Each fault is also displayed by flashing an onboard LED. See fault code section for flash codes.

The speed set-point is controlled by a 0 to 5 volt non-isolated analog input. The controller provides a TTL level tachometer output. Control and indicator signals connect to a eight pin Molex header. The motor drive transistors are cooled by a large aluminum finned



heat sink. A temperature sensor embedded in the heatsink measures the heatsink temperature. The motor controller will shut down the motor if the heatsink temperature exceeds 100° C. The heatsink provides the mounting points for the assembly with two threaded holes at each end. The heatsink is electrically isolated from the circuitry. There is no input fusing or reverse polarity protection provided. The controller is specified to operate at an ambient temperature from 0° to 65° C. The PCA is coated with a type SR (silicone resin) based material to protect it from corrosion. Material is UL recognized. The controller is capable of controlling the following compressor models.

SIERRA04-0434Y3

SIERRA04-0982Y3

Note: See sales representative for complete list.

Operation

Power On/Off Switch

There are two options for switching the controller on and off. **Option one** applies continuous power to the controller, and a low current switch to enable (turn on) the drive. With this option a small amount of leakage current will be present in the off state. **Option two** is to use a high current switch to apply power to the controller with a jumper connected to enable the drive. With this option there is no leakage current in the off state. With either option the onboard microcontroller will start a 2 second delay timer, which allows time for the power supply to stabilize. After the delay, the motor will start running the motor at 3000 RPM for a period of 30 seconds in order to ensure proper oiling of the compressor.

Note: The controller presents a capacitive load to the system. On initial application of power, a substantial in-rush current will result if not limited by external components.

Speed Control

The speed set-point is controlled by a zero to five volt analog non-isolated input. Zero through one volt commands 1800 RPM, 4.75 to 5 volts commands the maximum speed of 6500 RPM. At startup the motor controller will run the motor at 3000 RPM for a period of thirty seconds in order to ensure proper oiling of the mechanism and after thirty seconds the controller will run the motor at the commanded speed. If for any reason (such as excessive load or low voltage) the motor should slow down to 1500 RPM the controller will output a fault and the motor will be shut down due to a low speed. The compressor needs to run faster than 1500 RPM for proper oiling. The motor controller will run the motor at the set-point speed independent of the load on the motor and the motor voltage provided that the speed is not limited by the motor voltage or current limit. Five volts and ground are available on the control connector. Connect five volts to one

leg of a 10K Ohm potentiometer. Connect the other to ground. Connect the wiper of the potentiometer to the speed input for variable speed operation.

Tachometer Output

A 0 to 5 volt non-isolated tachometer pulse indicates motor speed. The frequency (F) of the pulse is proportional to motor speed. Motor RPM = 2.5 X F in Hz.

Fault Indicator Output

The controller will signal a fault condition by outputting a logic high value on the fault output at JP5 pin 8. The controller also indicates a fault condition by flashing the on board fault LED. The Flashing pattern will be ¼ second on and ¼ second off for each count then dwell 2 1/2 seconds and repeat until the fault(s) are cleared. Listed below are the fault codes.

- 1 flash – Over Current
- 2 flashes – Over Voltage
- 3 flashes – Under Voltage
- 4 flashes – Controller Overheat
- 5 flashes – Motor Overheat
- 6 flashes – Stalled
- 7 flashes – Low Speed
- 8 flashes – Startup Failed

Fan Power

An option is provided for two 2 pin straight friction lock connectors which each provide a regulated 12 volts and ground for powering two DC fans if required. Whenever the control circuitry is switched on power is provided to these two connectors.

Electrical Ratings / Specifications

Absolute Maximum Ratings

Parameter	Min.	Max.	Units
V _M	0	63	V
Speed Set-point	-0.3	5.05	V
Power On/Off	0	63	V
Fault output current sourced		-4	mA
Fault output current sunk		4	mA

Electrical Characteristics

Parameter	Conditions	Min.	Nom.	Max.	Units
V _{CC}	I _{OUT} < 50 mA	4.75	5.0	5.25	V
Tachometer					
Output Low Voltage	I _{OL} = 0.4 mA			0.6	V
Output High Voltage	I _{OH} = -0.1 mA	2.2			V
Fault					
Output Low Voltage	I _{OL} = 1 mA			0.6	V
Output High Voltage	I _{OH} = -1 mA	4.05			V
Voltage Fault					
High Voltage Shutdown		57.9	59.9	61.9	V
High Voltage Resume		56.9	58.9	60.9	V
V _{HS} - V _{HR}		1			V
Low Voltage Shutdown		36	37	38	V
Low Voltage Resume		37	38	39	V
Temperature Fault					
High Temp Shutdown		95	100	105	°C
High Temp Resume		90	95	100	°C
T _{HS} - T _{HR}		5			°C
V_M					
Operating Range		38		57	V
Current	Power On/Off >= 9 V (Note 1)			45	A
JP2/JP3 Fan Power					
JP2	100ma Maximum	11.4	12	12.6	V
JP3	100ma Maximum	11.4	12	12.6	V
Motor Speed					
Minimum Speed	Command voltage 0V to 1V	1700	1800	1900	RPM
Maximum Speed	Command voltage 4.75V to 5V	6400	6500	6600	RPM
Note 1: Measured current is steady state. The controller presents a capacitive load to the system. On initial application of power, a substantial in-rush current will result if not limited by external components.					

Connectors

Power

Motor power (V_M) is supplied through the power connector. The power connector is a Packard Metri-Pack 630 series part number 12129938. The mating connector part number is 12129939.

Pin	Signal Name	Type
J1	+48 Volts	Input
J2	Ground	Input

Control

The control connector, reference designator JP5, is an eight pin shrouded header, Molex part number 70543-0042. The mating connector is Molex part number 50-57-9408.

JP1

Pin	Signal Name	Type
1	NC	NC
2	Ground	Output
3	Power On/Off	Input
4	+Vm EXT	Output
5	Tachometer	Output
6	+5 Volts	Output
7	Speed set-point	Input
8	Fault	Output

Fan Power

The unit provides two fan power connectors JP1, and JP2. The connectors provide regulated 12 VDC. The connectors are 2 pin straight friction lock headers Molex part number 22-23-2021 mating connector 22-01-2027.

JP1

Pin	Signal Name	Type
1	+12 Volt Fan High	Output
2	Ground	Output

JP2

Pin	Signal Name	Type
1	+12 Volt Fan High	Output
2	Ground	Output

Compressor

The compressor wire harness connector is a Packard Metri-Pack 630 series part number 12052623. The mating connector part number is 12015664.

Pin	Signal Name	Type
A	Phase A	Output
B	Phase B	Output
C	Phase C	Output
D	Not used	

Shell Temperature Switch

The shell temperature switch wire harness connector is an AMP Universal Mate-N-Lock part number 350778-1. The mating connector part number is 350777-1. Connect to a normally closed switch.

Serial Port

The serial Port connector (JP5) is a 4 Pin shrouded header with latch Molex part # 70543-0038, mating connector is Molex part number 14-56-7042.

JP3

Pin	Signal Name	Type
1	Vcc	
2	Data	I/O
3	Clock	I/O
4	Ground	

The serial interface is configured for 19.2 K baud, 8 data bits, 1 stop bit, no parity, and no flow control. The controller will report the following operating parameters once per second over the serial interface:

- Temperature - heatsink temperature in °C
- Power Supply – Volts
- Current – average current delivered to motor
- Motor Speed – actual speed in RPM
- Fault – in the event of a fault a brief description of the fault is reported (see below)

Fault Reporting	
STALLED	If the controller detects a locked rotor it will shut down the motor, delay for 20 seconds and attempt to restart the motor. The controller will continually attempt to restart the motor. After ten attempts the fault indicator will be activated.
STARTUP FAILED	The controller will detect if the motor has failed to start. After a 20 second pause the controller will attempt to restart the motor. The controller will continually attempt to restart the motor. After ten attempts the fault indicator will be activated.
MOTOR OVERHEAT	If the compressor shell temperature switch opens, the controller will shut down the motor and delay for 5 seconds. The controller will indicate the fault condition by activating the fault indicator. After the delay period the controller will recheck the compressor shell temperature switch state. If the compressor shell temperature switch is closed the controller will restart the motor and deactivate the fault indicator.
UNDER / OVER VOLTAGE	If the motor voltage is outside of the operating limits, the controller will shut down the motor and will delay for 10 seconds. After the delay period, the controller will recheck the voltage conditions. If the voltage is within the operating limits the motor will restart.
OVER CURRENT	Hard current limit – if the controller detects an over-current condition it will shut down the motor and activate the fault indicator. The controller will delay 60 seconds then attempt to restart. After 10 over current faults the power must be cycled to clear this fault.
CONTROLLER OVERHEAT	If the controller (heatsink) temperature rises above 100°C the controller will shut down the motor and delay for 10 seconds. After the delay period the controller will recheck the module temperature. If the temperature has fallen below 95 °C the controller will restart the motor. The controller will indicate a fault condition by activating the fault indicator. The controller will continue to monitor the heatsink temperature. The controller will restart the motor and deactivate the fault indicator when the heatsink temperature falls below 95 °C.
LOW SPEED	The compressor must maintain a minimum speed of 1500 RPM for proper lubrication. If the controller detects a low speed condition, it will shut down the motor, delay for 20 seconds and attempt to restart the motor. If the motor does not restart after 10 attempts, the controller will indicate a fault condition by activating the fault output. The controller will continually attempt to restart the motor. If the controller is successful in restarting the motor and maintaining a speed above 1500 RPM for 30 seconds, the fault indicator will be deactivated

Firmware Port

The PCB includes provision for a firmware port which is a 10 dual row header (JP7) Molex part # 90131-0125, mating connector is Molex part number 90143-0010.

JP4

Pin	Signal Name	Type
1	Ground	Input
2	Icc Data	Input/Output
3	Ground	Input
4	Icc Clock	Input/
5	Ground	Input
6	Reset	Input
7	Vcc	Output
8	Vpp	Input
9	N.C.	N.C.
10	Ground	Input